

## ROUTING SLIP

FROM

Health

ATTENTION OF

TO:

CITY HALL OFFICES☐ Building Regulations☐ City Attorney☐ City Clerk☐ Mayor/City Council☐ City Manager☐ Word Processing☐ Community Develop.☐ Advanced Planning☐ Economic Develop.☐ Finance☐ Accounting☐ Licensing☐ Purchasing☐ Health☐ Air Pollution☐ Clinic☐ Personnel☐ Public Works☐ Engineering☐ General Services☒ Sanitary Services☐ Street Maintenance☐ Traffic

*Bob Schaefer*  
*Bob Schaefer*

OTHER OFFICES☐ Airport☐ Art Museum☐ Chamber of Commerce☐ Children's Home☐ City Utilities☐ Communications☐ Fire Department☐ Human Resources☐ Library☐ Municipal Court☐ Parks☐ Police Department☐ Watershed Mgmt.

INSPECT, IF  
CONFIRMED,  
LET PEARL  
KNOW WE  
WILL REFER  
TO D.N.R.

*called Pearl*

*5/12/84*

City of Springfield  
Water Pollution Control Section  
Pollution Complaint/Report Form

Date 5/11/89

Report From:

☐ Citizen

☒ Fire Dept

☐ Sewer Maintenance

☐ Other

Received By: Joyce Seders

Referred To: Karen Chandler

Date of Incident: \_\_\_\_\_

Complainant Information:

Name unknown

Address \_\_\_\_\_

Phone \_\_\_\_\_

Directions(if needed) \_\_\_\_\_

Responsible Party Information:

Name DTD Drainage

Address 1950 E. Keweenaw

Phone \_\_\_\_\_

Possible contamination of: ☐ soil ☐ groundwater

☒ surface water what body? \_\_\_\_\_

☐ other \_\_\_\_\_

Other Pertinent Information \_\_\_\_\_

Who to contact:

☐ DNR 417-883-4033

☐ DNR 314-634-2436

☐ EPA 913-236-3378

☐ Fire Dept 864-1719

☐ Police Dept 864-1719

☐ Bob Schaefer

☐ CU 831-8320

☐ Street Dept

☐ Health Dept

☐ Sewer Maint

☐ Sewer Const

☐ Chemtrec 800-424-9300

☐ DOT

☐ NRC 312-790-5500

☐ Other \_\_\_\_\_

Details of Incident:

Jack See received a call that DTD Drainage was cleaning radiators and the discharge was running into the storm sewer. The caller said that runoff was carrying sediments into the storm sewer.

Action needed:

I checked DTD Drainage's lot. There was oil from the fenced area running out on the lot which was gravel. There were streams of what looked like transmission fluid and antifreeze on one side of the lot. Streams of oil were coming down the lot from the vehicle door and the oil had run into the storm sewer in the front. There were a couple of gallons lying in the storm sewer too. I talked to Randy Dwyer about this finding when I got there. I then called DNR.

1950 E. Keweenaw



### Investigation Results

and told Gale Roberts about it. He said  
Quick Kroc's would send them a letter.  
On May 12, 1989, Pearl from Pearl & Jesus  
restaurant next door to PTD Manager, called  
the Health Dept about the oil on the lot. The  
Health Dept turned the complaint to us.  
I called Pearl and told her the complaint had  
been referred to DNR.

CITY OF SPRINGFIELD  
CITIZEN REQUEST

MAY 11 1989

DATE: 05/10/89  
TIME: 00:00:00

ABATE DATE:  
ASSIGN: REFERRED

COMPLAINANT: PEARL OF PEARL & VERN'S ADDRESS: 1950 E. KEARNEY  
PROBLEM: DIESEL OIL RUNNING DOWN DRIVE AND INTO DRAIN  
LOCATION: GARAGE BEHIND 1950 E. KEARNEY

PROPERTY OWNER: \_\_\_\_\_ OWNER'S ADDRESS: \_\_\_\_\_  
OCCUPANT: \_\_\_\_\_ COMMENT: \_\_\_\_\_ PRG REP (Y/N): \_\_\_\_\_  
PHONE#: \_\_\_\_\_ BY: VJS CNTRL# 1216 CODE: 9 ZONE: I-1  
DATE INVESTIGATED: \_\_\_\_\_ TIME \_\_\_\_\_ am \_\_\_\_\_ DATE OF  
\_\_\_\_\_ pm BY \_\_\_\_\_ FINAL ABATEMENT \_\_\_\_\_

FINDING: \_\_\_\_\_  
ACTION: \_\_\_\_\_

SUBSEQUENT INVESTIGATION

DATE:	FINDING:	ACTION:
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

NOTES:

PROGRESS REPORT DATE: \_\_\_\_\_ TIME: \_\_\_\_\_ VIA: \_\_\_\_\_  
DID THIS REQUIRE COURT ACTION? \_\_\_\_\_ REVIEWED BY: \_\_\_\_\_

City of Springfield  
Water Pollution Control Section  
Pollution Complaint/Report Form

Date 2/21/89

Report From:

- ☒ Citizen  
☐ Fire Dept  
☐ Sewer Maintenance  
☐ Other PEARL + VERN'S CAFE

Received By: FIRE DEPT.

Referred To: WATER POLLUTION CONTROL \*

Date of Incident: 2/20/89

\* J. RANDALL LYMAN

Complainant Information:

Name PEARL + VERN'S CAFE  
Address 1950 E. KEARNEY (FRONT)  
Phone 866-0329  
Directions (if needed) \_\_\_\_\_

Responsible Party Information:

Name D. T. D. DRAYAGE  
Address 1950 E. KEARNEY (REAR)  
Phone 831-5011  
OFFICE - 1408 W. WATER  
WAYNE AGE, OPERATIONS  
MANAGER

Possible contamination of: ☒ soil ☐ groundwater

☒ surface water what body? STORM SEWER  
☐ other ON KEARNEY ST. TO

Other Pertinent Information \_\_\_\_\_

N. E. CORNER OF  
NORTHTOWN MALL  
PARKING LOT.

Who to contact:

- |  |                                       |  |
|--|---------------------------------------|--|
| <input checked="" type="checkbox"/> DNR 417-883-4033 | <input type="checkbox"/> Bob Schaefer | <input type="checkbox"/> Sewer Const           |
| <input checked="" type="checkbox"/> DNR 314-634-2436 | <input type="checkbox"/> CU 831-8320  | <input type="checkbox"/> Chemtrec 800-424-9300 |
| <input checked="" type="checkbox"/> EPA 913-236-3378 | <input type="checkbox"/> Street Dept  | <input type="checkbox"/> DOT                   |
| <input type="checkbox"/> Fire Dept 864-1719          | <input type="checkbox"/> Health Dept  | <input type="checkbox"/> NRC 312-790-5500      |
| <input type="checkbox"/> Police Dept 864-1719        | <input type="checkbox"/> Sewer Maint  | <input type="checkbox"/> Other _____           |

Details of Incident: DIESEL FUEL DRAINED FROM SADDLE  
TANK ON OLD SEMI TRACTOR ON PARKING LOT IN  
FRONT OF 1950 E. KEARNEY, TO STORM SEWER  
ON E. KEARNEY, AND NORTHERLY TO EARTHEN  
STORM DITCH N.E. OF NORTHTOWN MALL - PARKING  
LOT. RAINFALL HAD OCCURRED EARLIER IN THE  
DAY WAS ON TOP OF PUDDLES AND CARRIED  
AWAY BY RAINFALL.

Action needed: REMOVE PUDDLES OF OIL ON FRONT  
PARKING LOT. ADVISED TO PLACE SORBENT (HAY)  
IN STORM DITCH N.E. OF NORTHTOWN MALL AND  
SUBSEQUENTLY REMOVE OIL SOAKED SORBENT  
AND DISPOSE OF IN SOLID WASTE DUMPSTER.

J.R.A.

1950 E. Kearney



# Investigation Results

2/20/89 - PAGED BY FIRE DEPARTMENT - 10:45 A.M.

2/20/89 - ARRIVED ON SCENE ~ 11:10 A.M.

REPORTED TO DAN WHISLER, FIRE MARSHAL  
AND BATTALION CHIEF JACKSON.

NO HEALTH DEPT. REPRESENTATIVE ON SITE. JAL

✓ 11:20 WORKERS INSIDE GARAGE AT 1950 E. HEARNEY SAID THEY  
DID NOT SEE OIL LEAK AND DID NOT OPEN VALVE ON  
FUEL TANK. SAID THEY BURN ANY WASTE FUEL  
AND OIL IN WASTE OIL HEATER. MARSHAL  
WHISLER CALLED WAYNE AGEE, OPERATIONS MGR.,  
TO SCENE. JAL

✓ 11:40 WAYNE AGEE ARRIVED. MR. WHISLER ASKED ME  
TO INFORM MR. AGEE WHAT CLEANUP WAS REQUIRED.  
BAT. CHIEF JACKSON SAID HE HAD ORDERED A LOAD  
OF SAWDUST FROM SERVICE CENTER. JAL  
TOLD MR. AGEE TO CALL MDNR + EPA. TO REPORT SPILL - 24 HRS. J

✓ 12:00 NOON - I TOLD MR. AGEE ALL OIL SHOULD BE  
CLEANED UP ON FRONT LOT AND OIL SKIMMED  
OFF WATER IN STORM DITCH N.E. OF NORTHTOWN  
MALL PARKING LOT. MR. AGEE SAID HE  
DID NOT WANT TO BUY SAWDUST FROM CITY,  
HE WOULD USE AIR PUMP TO SUCK UP OIL  
FROM PUDDLES INTO 55 GAL DRUMS. JAL

✓ 12:10 I TOLD FIRE BAT. CHIEF JACKSON, MR  
AGEE DID NOT WANT SAWDUST. MR. JACKSON  
SAID THAT WAS FINE AND THAT THEY WOULD  
LEAVE IT WITH ME. PUMPER AND BAT.  
CHIEF LEFT SCENE. MR. WHISLER  
LEFT SCENE. JAL

✓ 12:15 MR. AGEE AND EMPLOYEES HAD CLEANED UP  
MOST OF THE OIL. HAD PROBLEMS WITH  
GETTING POWER TO AIR COMPRESSOR FOR  
PUMP. TOOK MR. AGEE AND EMPLOYEE TO  
NORTHTOWN MALL PARKING LOT. INSTRUCTED THEM  
TO SKIM OIL OR REMOVE. SAID THEY WOULD  
GET HAY AND ADSORB OIL IN STORM DITCH.

1:15 P.M. - I LEFT SCENE - JAL 6 HRS COMP. ELAPSED

2/21/89 I INSPECTED FRONT LOT AT 1950 E. HEARNEY.  
LOT CLEANED UP VERY WELL. STRAW (HAY) STILL  
11:00 A.M. IN STORM DITCH. TALKED TO D.M.R. AT 10:00 A.M.  
AGEE HAD NOT CALLED THE S.R.O. ABOUT THE SPILL.  
JAL

1 HR. REC.

### Investigation Results


2-23-89 10:00 A.M. - GENE PABST INSPECTED, HAY  
AND OIL NOT REMOVED FROM STORM DITCH. *gma*  
1 HR. REG.

2-24-89 10:30 A.M. - GENE PABST INSPECTED, HAY  
AND OIL STILL NOT REMOVED FROM DITCH. *gma*  
1 HR. REG.

3/1/89 2:15 P.M. - R. LYMAN INSPECTED. HAY  
AND OIL STILL IN DITCH. TALKED TO SHOP  
WORKER AT 1950 E. KEARNEY. HE SAID HE WOULD  
PICK UP HAY ON 3/2/89 AND DISPOSE OF IN  
TRASH. *gma* 1 HR. REG.

3/2/89 1:45 P.M. HAY NOT REMOVED. *gma* 0.5 HR. REG.

3/13/89 2:30 P.M. HAY REMOVED *gma*  
CONSIDERABLE OIL OBSERVED ON SURFACE  
ATTRIBUTABLE TO STREET AND PARKING LOT  
RUNOFF AFTER MELT OF 14" SNOW  
LAST WEEK. *gma* 1 HR. REG.



OPEN  
DITCH

OIL POOL  
W/ STRAW  
ABSORBENT

STORM SEWER

NORTH TOWN  
MALL

STORM  
SEWER

E. KEARNEY

SPILL  
SITE

PEARL &  
VERN'S  
CAFE

1950

D.T.D.  
TRUCKING



JOHN ASHCROFT

Governor

G. Tracy Mehan, III  
~~FREDERICK A. ASHCROFT~~

Director



STATE OF MISSOURI  
DEPARTMENT OF NATURAL RESOURCES

DIVISION OF ENVIRONMENTAL QUALITY

Springfield Regional Office  
1155 East Cherokee Street  
Springfield, MO 65807  
417-883-4033

MAY 15 1989

Division of Energy  
Division of Environmental Quality  
Division of Geology and Land Survey  
Division of Management Services  
Division of Parks and  
Historic Preservation

Greene County/HzW  
General

CERTIFIED MAIL  
P 035 184 515

May 11, 1989

Ms. Carol Wilburn  
DTD Drayage Co.  
1408 West Water  
Springfield, MO. 65802

Dear Ms. Wilburn:

This is office is in receipt of your letter dated May 9, 1989 regarding application for resource recovery certification for the waste oil burner at the DTD Drayage Company in Springfield, Missouri.

Please note, that if the burner will not be used it is not necessary for you to submit a completed application for resource recovery certification. You should note however that if the company generates more than 220 pounds of waste oil in any one month or accumulates that much at any one time, you must register as a waste oil generator. The regulated amount of 220 pounds is about 27 gallons. A waste oil generator form is enclosed.

You should also note that on May 10, 1989, this office received a call from the Springfield Sanitary Services Department advising us that they had received a complaint concerning the possible dumping of waste oil and transmission fluid at your business.

Please note that proper handling of waste oils is necessary to prevent contamination of streams and waterways. Any discharge of waste oil into waters of the state is a violation of the state Clean Water Law. Also note that disposing of waste oils into the environment is a violation of the state Hazardous Waste Regulations and possibly of the public nuisance law.

REG 1950 E. KEARNEY

Ms. Carol Wilburn  
Page 2  
May 11, 1989


Any pooled oil should be recovered and any soils that are saturated with the oil should be removed and disposed of properly. The Springfield Sanitary Landfill has been accepting oil contaminated soil if special waste disposal approval is obtained. A request form has been enclosed for your use.

If you do not plan to use the waste oil burner in the future you must properly dispose of the oil. There is at least one company in Southwest Missouri that provides a disposal service for waste oil. We can provide you with further information regarding them upon request.

Please advise this office of your progress in the cleanup of the oil contaminated soil and your plans for handling and disposing of waste oil in the future. If you are generating a regulated amount of waste oil, the registration form should be submitted immediately with a copy sent to this office. Your response by May 23, 1989 will be expected. If you have any questions, feel free to contact us.

Sincerely,

SPRINGFIELD REGIONAL OFFICE



Charles L. Kroeger  
Environmental Specialist

Enc

cc: Springfield Sanitary Services  
Waste Management Program, Enforcement Unit

1950 E. Kearney



CITY OF SPRINGFIELD  
INTER-OFFICE MEMORANDUM

ATTENTION OF \_\_\_\_\_ FILE \_\_\_\_\_

DATE 11-7-86

DEPARTMENT \_\_\_\_\_

Re: Gasoline in the sanitary sewer - 1950 East Kearney

I received a call (11-6-86, 2:00 P.M.) from unit 552 stating that they had been flushing the sewer in front of Pearl & Vern's, 1950 E. Kearney, and observed a gasoline odor. I went to that location and checked M.H.'s #15, #16 & #17, Wye Map G-13 and M.H. #10, Wye Map G-14 and obtained a zero (0) reading. We will monitor the area closely for the next few days.

SIGNED \_\_\_\_\_ Gene Pabst

1950 E. KEARNEY

Rub Oil Co.

owned by Tom Underwood

Box 8

Rogersville Mo.

Spill at: Skelly Station  
1950 E. Kearney

Driver: Jeff Saddle  
~ 100 gallons of gasoline

witness: Richard John Zirgibel  
234 S. Main  
Republic, Mo. 732-2590

1950 E. KEARNEY



May 23, 1983

Mr. Tom Underwood  
Rub Oil Co.  
1205 W. Division  
Springfield, MO 65802

Dear Mr. Underwood:

On May 16, 1983 a Mr. Jeff Saddler, a driver for Rub Oil Company, spilled approximately 100 gallons of gasoline at the Skelly Station (1950 E. Kearney).

The City of Springfield has a provision in the City's ordinances to recover costs incurred for labor and materials involved in gas and oil spills.

The total cost for the City's expenses is \$63.33, \$25.00 of which was sawdust and the remaining \$38.33 was for labor and equipment costs.

The payment of \$63.33 should be made to the Director of Finance, City of Springfield, Missouri and sent to:

Mr. Robert R. Schaefer, P.E.  
City Hall, Room 210  
830 Boonville  
Springfield, MO 65802

If you have any questions pertaining to this spill, please feel free to call 864-1924.

Sincerely,

J. D. Slaughter  
Water Pollution Control Inspector II  
Surveillance & Enforcement

JDS:js

cc: Robert R. Schaefer, P.E., Superintendent of Sanitary Services

1950 E. KEARNEY